



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title N1102.3.3 Glazed fenestration exemption		Page 470
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29 th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change the 1st line of N1102.3.3 to read as follows:</p> <p>Up to 15 square feet (1.4m²) of glazed fenestration per dwelling unit shall be permitted to be exempt from U-factor and SHGC requirements in Section N1102.1.</p>		
REASON AND FISCAL IMPACT		
<p>SHGC requirements do not apply to Indiana (climate zones 4 & 5).</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		